

**§ 830.202 Safety basis.**

(a) The contractor responsible for a hazard category 1, 2, or 3 DOE nuclear facility must establish and maintain the safety basis for the facility.

(b) In establishing the safety basis for a hazard category 1, 2, or 3 DOE nuclear facility, the contractor responsible for the facility must:

(1) Define the scope of the work to be performed;

(2) Identify and analyze the hazards associated with the work;

(3) Categorize the facility consistent with DOE-STD-1027-92 (“Hazard Categorization and Accident Analysis Techniques for compliance with DOE Order 5480.23, Nuclear Safety Analysis Reports,” Change Notice 1, September 1997);

(4) Prepare a documented safety analysis for the facility; and (5) Establish the hazard controls upon which the contractor will rely to ensure adequate protection of workers, the public, and the environment.

(c) In maintaining the safety basis for a hazard category 1, 2, or 3 DOE nuclear facility, the contractor responsible for the facility must:

(1) Update the safety basis to keep it current and to reflect changes in the facility, the work and the hazards as they are analyzed in the documented safety analysis;

(2) Annually submit to DOE either the updated documented safety analysis for approval or a letter stating that there have been no changes in the documented safety analysis since the prior submission; and

(3) Incorporate in the safety basis any changes, conditions, or hazard controls directed by DOE.

**§ 830.203 Unreviewed safety question process.**

(a) The contractor responsible for a hazard category 1, 2, or 3 DOE nuclear facility must establish, implement, and take actions consistent with a USQ process that meets the requirements of this section.

(b) The contractor responsible for a hazard category 1, 2, or 3 DOE existing nuclear facility must submit for DOE approval a procedure for its USQ process by April 10, 2001. Pending DOE approval of the USQ procedure, the con-

tractor must continue to use its existing USQ procedure. If the existing procedure already meets the requirements of this section, the contractor must notify DOE by April 10, 2001 and request that DOE issue an approval of the existing procedure.

(c) The contractor responsible for a hazard category 1, 2, or 3 DOE new nuclear facility must submit for DOE approval a procedure for its USQ process on a schedule that allows DOE approval in a safety evaluation report issued pursuant to section 207(d) of this Part.

(d) The contractor responsible for a hazard category 1, 2, or 3 DOE nuclear facility must implement the DOE-approved USQ procedure in situations where there is a:

(1) Temporary or permanent change in the facility as described in the existing documented safety analysis;

(2) Temporary or permanent change in the procedures as described in the existing documented safety analysis;

(3) Test or experiment not described in the existing documented safety analysis; or (4) Potential inadequacy of the documented safety analysis because the analysis potentially may not be bounding or may be otherwise inadequate.

(e) A contractor responsible for a hazard category 1, 2, or 3 DOE nuclear facility must obtain DOE approval prior to taking any action determined to involve a USQ.

(f) The contractor responsible for a hazard category 1, 2, or 3 DOE nuclear facility must annually submit to DOE a summary of the USQ determinations performed since the prior submission.

(g) If a contractor responsible for a hazard category 1, 2, or 3 DOE nuclear facility discovers or is made aware of a potential inadequacy of the documented safety analysis, it must:

(1) Take action, as appropriate, to place or maintain the facility in a safe condition until an evaluation of the safety of the situation is completed;

(2) Notify DOE of the situation;

(3) Perform a USQ determination and notify DOE promptly of the results; and (4) Submit the evaluation of the safety of the situation to DOE prior to removing any operational restrictions